DOCUMENT 00490 ADDENDA

City of Santa Clara
Water and Sewer Utilities Department

Addendum Number: ONE

Project: NORTHSIDE TANKS SITE IMPROVEMENTS PROJECT

Invitation Number:

WA 30148

Date:

July 25, 2014

Bid Date:

July 30, 2014

Bid Opening:

3:00 P.M.

TO ALL BIDDERS:

The following changes, deletions, additions, and/or clarifications shall be made to the drawings and specifications for the work of the above Project:

SPECIFICATIONS:

- 1. Document 00520 Title "Agreement"
 - a. To account for the generator's lead time, the Substantial Completion date and Final Completion date as given in Items 3.1.1 and 3.1.2 respectively shall be extended by up to twenty (20) Calendar Days.
 - b. Add Item 3.1.3 "Contractor shall start securing the standby generator immediately after the Notice to Proceed is issued."
- 2. Document 16443 Title "Motor Control Center"
 - a. Add Item 2.1.A.5 "General Electric" to the list of acceptable manufacturers, which include Allen-Bradley, Cutler Hammer, Siemens Energy & Automation, Inc., and Square D Company.

This addendum is part of the Contract Documents and in case of conflict among drawings, specifications, and this addendum, the addendum shall govern.

Bidders shall acknowledge receipt of this addendum by inserting the addendum number and date and signing where indicated on DOCUMENT 00400, BID. Failure to do so may subject bidder to disqualification based upon a non-responsive bid.

Issued by the City of Santa Clara

Shilpa B. Mehta, P.E.

Principal Engineer - Water and Sewer

END OF DOCUMENT

00490 - 1 Addenda